

TYPE 1



TYPE 3-A



TYPE 2



TYPE 3-B



TYPE 2-A



TYPE 4



TYPE 2-B



TYPE 4-A



TYPE 4-C



TYPE 6



TYPE 7



TYPE 4-B



TYPE 8

NOTES

GENERAL: This drawing shows alternate types of curb that may be used on various types of pavement. The typical section of the project shows the type to be used, also the thickness of the edge of the pavement or the edge of the curb and gutter section.

JOINTS: 1" expansion joints shall extend up to the top of the curb and shall be constructed in the curb and gutter section in such a manner that the joint seal will extend the full width of the gutter and into the curb face a sufficient distance to seal the joint to an elevation of a least 2" above the flow line of the gutter. Dowel bars shall be used in the curb and gutter section at expansion joints and to the surface of the pavement.

Transverse expansion joint material shall meet the requirements of Item 705.03.

GUTTER PLATE THICKNESS: Thickness of gutter plate "T" shall be 9" unless otherwise shown on the plans.

TOLERANCES: Dimensional tolerances are as follows:

Curbs: -1/32" to +1/4".
Gutters: 0 to +1/2".

LEGEND

1 Expansion joint material and joint sealer are not required for the portion of the curb that is adjacent to a flexible pavement type. Both materials are required, as detailed, for the full height of rigid pavement and concrete bases.

2 Butt joints shall be provided between combined curb-and-gutter and new or existing rigid pavements, with tie bars or hook bolts provided at intervals of 5'. See SCD BP-2.1 for details of tie bars and hook bolts.

If the combined curb-and-gutter adjoins a new rigid base or an existing rigid base or pavement that is to be surfaced with bituminous material, a butt joint shall also be provided. However, tie bars or hook bolts shall be omitted when the vertical overlap ("V" in detail below) between the curb-and-gutter and rigid pavement is less than 7".



THIS DRAWING REPLACES BP-5.1 DATED 7-28-00.

STATE OF OHIO DEPARTMENT OF TRANSPORTATION
Michael Blue
ADMINISTRATOR
7-19-2013
DATE

STDS. ENGINEER M. Ruppe

OFFICE OF ROADWAY ENGINEERING

STANDARD ROADWAY CONSTRUCTION DRAWING
CONCRETE CURBS AND COMBINED CURB AND GUTTER

SCD NUMBER BP-5.1